




**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
RENEWAL of NO OBJECTION CERTIFICATE**



Ack. No.:	134720002018	
NOC:	0005211/RENEWAL/Medchal/2018	
NOC TYPE:	RENEWAL*	
Valid Upto:	05-08-2023	

Applicant Details:	CH BHADRAREDDY,8008044111,Sy.No.59,Jayanagar Colony,New Bownpally,Secunderabad.
Building for which NOC issued:	M/s Chandramma Educational Society(Mallareddy Hospital),Sy.No81,53,54,56,57,66,72,138,142&142,Suraram Village,Quthbullapur Mandal/-Jeedimetla/Qutubullapur/Medchal

Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:			No		
Plot Area (Sq. Mtrs):	16878.00	Height (Metres):	19.65		
Open Spaces (Metres):	North: 12.80	South: 7.00	East: (F) 14.80	West: 12.80	
No. of Floors: 0 Cellars, 0 Stilts, 1 Ground, 4 Floors, 0 Terrace			Occupancy Type:	INSTITUTIONAL C-1 Hospitals, Sanatoria and Nursing Homes	
Total Built-up Area (Sq.Mtrs):	16877.64		Staircases:	No. of Staircases Required/Proposed:	3
Fees Paid (₹):	22500			Aggregate Width Required/Proposed (Metres):	6.00

Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:

Fire Extinguisher:	96	First Aid Hose Reel:	18	Wet Riser:	4
Down Comer:	0	Yard Hydrant:	10	Automatic Sprinkler System:	1039
Manually Operated Electronic Fire Alarm Systems:	18	Terrace Tank (Litres):	25000		
Automatic Detection and Alarm System:	688	Underground Static Water Storage Tank (Litres):	100000		

Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm2 at Terrace Level	Type	Quantity	(Capacity in Litres/min)
	Electrical	2	2280
	Diesel	1	2280
	Jockey	1	180
Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm2	(Capacity in Litres/min)		
	900		

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

* For details and conditions of Renewal No Objection Certificate for Occupancy, refer overleaf".



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE**



The Renewal No Objection Certificate for Occupancy is issued subject to following conditions:

- On the basis of the recommendations of the building inspection committee, this Renewal No Objection Certificate for Occupancy is issued.
- Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.
- The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During the inspection, if any violation of No Objection Certificate for Occupancy conditions/non-functioning of fire safety systems is noticed, prosecution will be launched on the Owner/Occupier as per the provisions of Fire Service Act, 1999.
- It is the responsibility of the builder/management to apply for Renewal No Objection Certificate for Occupancy duly remitting the user charges as per G.O.Ms.No.71, (Home Prisons-A) Dep., dated: 01-04-2010, two months before expiry of this No Objection Certificate.
- f) The floor wise built-up areas of the building are as follows:

FloorType	BuildUpArea
Ground	4465.30
1st Floor	3855.09
2nd Floor	3855.09
3rd Floor	3855.09
4th Floor	847.07
Total	16877.64